



No. IN Q1805476



DEEPA ENTERPRISES

(Testing Laboratories)

TEST REPORT

Laboratory Plot No. 14BR, Leelawati Enclave, Tigaon Road, Mujeri, Ballabgarh, Partabhad (Hr)-121004
 Tel. Fax. 0129-2300753, (M) 9800137739, 9950235476, 9971178062
 Email: detl.rsv@gmail.com, info@detl.in, Website: www.detl.in

ULR No. TC541323000000378F

Page 01 of 01
DETL/23-24/0104

Issue Date: 26-06-2023

Issue To: **M/s Rashtriya virja nand andh kanya senior Secondary school**
J-Block, vikas puri,
New Delhi-110018, india

Sample ID :

Date of sample receipt: 23-06-2023

Sample drawn by: DETL

Job Order No.: 0531A

Reference No.: RvnaKsss/01

Sample Description: Drinking water from drinking stn.

TEST RESULTS

PERIOD OF ANALYSIS

23-06-2023 to 26-06-2023

Reference IS:10500: 2012
TESTING PROTOCOL

Quantity	Container detail	Seal/Unseal	Appearance
2000ml	Sterilized bottle	Sealed	Clear
Preservation	Subcontracting	Sampling method	Dev. from std. method
Preserved	NA	APHA 24 th Edi 1060B	As per Test Method

PARAMETERS	TEST METHOD	RESULTS	UNITS	LIMITS (MAX.)	
				Desirable	Permissible
pH value (at 25.0 °C)	IS: 3025:Pt-11	6.76	...	6.5 to 8.5	
Calcium (as Ca)	IS:3025:Pt-40	2.4	mg/l	75	200
Total hardness (as CaCO ₃)	IS: 3025:Pt-21	22.0	mg/l	200	600
Iron (as Fe)	IS: 3025:Pt-53	<0.10	mg/l	0.3	No relaxation
Chloride (as Cl)	IS: 3025:Pt-32	16.0	mg/l	250	1000
Total Dissolved solids	IS: 3025:Pt-16	102.0	mg/l	500	2000
Sulphate (as So ₄)	IS: 3025 Pt-24	2.6	mg/l	200	400
Conductivity (at 25.0 °C)	IS: 3025:Pt-14	155.2	µmhos/cm	-	-
Colour	IS: 3025:Pt-4	<5.0	Hazen	5	15
Odour	IS: 3025:Pt-5	Agreeable	Agreeable	
Turbidity	IS: 3025:Pt-10	<1.0	NTU	1	5
Residual Free Chlorine	IS: 3025:Pt-26	<0.1	mg/l	0.2Min. When chlorinated	

REMARKS:

 Analyst

 AUTHORISED SIGNATORY


- Note
1. Sample will be retained only for One Week .
 2. The result listed refer only to the sample and applicable parameters endorsement of product is neither inferred nor implied.
 3. The result given above are related to the tested sample. As received and mentioned parameters. The customer asked for the above tests only



No -IN Q1865876

DEEPA ENTERPRISES

DETL/FGEN01/017

TEST REPORT

(Testing Laboratories)

Laboratory : Plot No. 148B, Leelawati Enclave, Tigaon Road, Mujeri, Ballabgarh, Faridabad (Hr) -121004

Tel. Fax: 0129-2300753, (M): 8800137739, 9958235476, 9971178062

Email: detl.rsv@gmail.com, info@detl.in, Website: www.detl.in

R No. DETL2300443A

Page 01 of 01
DETL/23-24/0100

Issue Date: 26-06-2023

Sample ID :

Issue To : **M/s Rashtriya virja nand andh kanya senior**
Secondary school
J-Block,vikas puri,
New Delhi-110018,india

Date of sample receipt: 23-06-2023

Sample drawn by: DETL

Job Order No.: 0588b

Reference No.: Rvnaksss/01

Sample Description: Drinking water from drinking stn.

TEST RESULTS

PERIOD OF ANALYSIS

Quantity	Container detail	Seal/Unseal	Appearance
500 ml	Sterilized bottle	Sealed	Clear
Preservation	Subcontracting	Sampling method	Dev. from std. method
Preserved	NA	APHA 24 th Edi 1060B	As per Test Method

23-06-2023 to 26-06-2023

Reference IS:10500:2012

TESTING PROTOCOL

PARAMETERS	TEST METHOD	RESULTS	UNITS	LIMITS (MAX.)	
				Desirable	Permissible
Coliform Organism	IS:1622-1981	Absent	mpn/100ml	Shall not be detectible	



REMARKS:

Analyst

AUTHORISED SIGNATORY

- Note:
1. Sample will be retained only for One Week .
 2. The result listed refer only to the sample and applicable parameters endorsement of product is neither inferred nor implied.
 3. The result given above are related to the tested sample. As received and mentioned parameters. The customer asked for the above tests only.